

## Karachi, Pakistan

### Meterological Conditions at Cavalier Energy Corporation 800MW Power Plant Site

Month	Average Sunlight (hours)	Temperature				Discomfort from heat and humidity	Relative humidity		Average Precipitation (mm)	Wet Days (+0.25 mm)
		Average		Record			am	pm		
		Min	Max	Min	Max					
Jan	9	13	25	4	32	Moderate	63	45	13	1
Feb	9	14	26	6	34	Moderate	72	49	10	1
March	9	19	29	8	41	Medium	79	57	8	1
April	10	23	32	14	44	High	87	62	3	0.2
May	10	26	34	18	48	Extreme	88	68	3	0.1
June	8	28	34	20	46	Extreme	86	69	18	1
July	4	27	33	23	43	Extreme	88	73	81	2
Aug	5	26	31	23	37	High	90	74	41	2
Sept	7	25	31	21	41	High	89	71	13	1
Oct	9	22	33	14	42	High	83	57	0	0.1
Nov	9	18	31	9	38	Medium	68	49	3	0.3
Dec	9	14	27	4	33	Moderate	64	45	5	1